f **y** 🖸 🦞 ⊠

**OSHA** 

Find it in OSHA

Q

For Workers For Employers Law & Regulations Data & Statistics Enforcement Training & Education

News & Publications • En Español About OSHA A to Z Index Contact Us FAQs What's New

OSHA News Release - Table of Contents

# **OSHA Regional News Release**

U.S. Department of Labor Office of Public Affairs

Region 5

May 12, 2016

OSHA finds refrigeration warehouse lacked proper procedures for handling ammonia

Employer name: Ozburn-Hessey Logistics LLC

Fond Du Lac, Wisconsin

Citations issued: May 5, 2016

**Investigation findings:** The U.S. Department of Labor's Occupational Safety and Health Administration issued nine serious and two other-than-serious violations to Ozburn-Hessey Logistics LLC. A January 2016 complaint investigation found the manufacturer violated OSHA's process safety management procedures for ammonia used in the company's refrigeration warehouse facility where more than 10,000 pounds of ammonia are in use.

An investigation by the agency's Appleton area office found the company failed to:

- Correct ice buildup, blistered and rusted piping on ammonia lines.
- Develop operational procedures to maintain the ongoing integrity of refrigeration equipment.
- Develop procedures for the safe completion of refrigeration related tasks while working at elevations.
- Document inspections and maintenance for the ammonia refrigeration evaporator condenser.
- Ensure piping and instrumentation diagrams are accurate.
- Provide clear instructions to employees to mitigate ammonia releases during service and maintenance.
- Provide personal protective and detection equipment necessary in the event of ammonia release.
- Keep catwalks and passageways in good repair.

**Quote:** "Exposure to ammonia can cause serious eye, throat and respiratory issues for employees," said Robert Bonack, OSHA's area director in Appleton. "When highly hazardous chemicals are not properly controlled and stored there is a potential for unintentional release. Companies that use refrigeration ammonia must carefully monitor their processes to ensure safe use."

Proposed Penalties: \$42,000

View Citations here\*.

Based in Brentwood, Tennessee, the global supply company has 120 locations worldwide employing more than 10,000 workers.

To ask questions, obtain compliance assistance, file a complaint, or report amputations, eye loss, workplace hospitalizations, fatalities or situations posing imminent danger to workers, the public should call OSHA's toll-free hotline at 800-321-OSHA (6742) or the agency's Appleton Area Office at 920-734-4521.

# # #

### **Media Contacts:**

Scott Allen, 312-353-6976, allen.scott@dol.gov Rhonda Burke, 312-353-6976, burke.rhonda@dol.gov

Release Number: 16-935-CHI

2016 - 05/12/2016 - OSHA finds refrigeration warehouse lacked proper procedures for handling ammonia Page 2 of 2 departmental information and documents into alternative formats, which include Braille and large print. For alternative format requests, please contact the department at (202) 693-7828 (voice) or (800) 877-8339 (federal relay).

\*Accessibility Assistance: Contact OSHA's Office of Communications at 202-693-1999 for assistance accessing PDF materials.

OSHA News Release - Table of Contents

UNITED STATES
DEPARTMENT OF LABOR

Career & Internships | Contact Us



Occupational Safety & Health Administration 200 Constitution Ave., NW, Washington, DC 20210 800-321-OSHA (6742) TTY www.OSHA.gov

## **ABOUT THE SITE**

Freedom of Information Act Privacy & Security Statement Disclaimers Important Web Site Notices Plug-ins Used by DOL RSS Feeds from DOL Accessibility Statement

Frequently Asked Questions

## LABOR DEPARTMENT

Español
Office of Inspector General
Subscribe to the DOL Newsletter
Read The DOL Newsletter
Emergency Accountability Status Link
A to Z Index

## FEDERAL GOVERNMENT

White House
Affordable Care Act
Disaster Recovery Assistance
USA.gov
Plain Writing Act
Recovery Act
No Fear Act
U.S. Office of Special Counsel